

NLDC SCED_MTL for Date 'D': 01-04-2025 (published on D-1 basis: 31-03-2025 at 2030 hrs)

S.NO.	GENERATORS	REGION
1	Mauda	WR
2	Mauda 2	WR
3	NTPL	SR
4	Kudgi-1	SR
5	Dadri Stage 1	NR

Notes:

- 1) List of power plants with Schedule < Minimum Turndown Level (MTL) are shown in the above table. Power plants that have already received SCUC =yes for the next day are excluded from this list.
- 2) Power plants with Schedule < MTL during any time block in Off-Peak hours AND Schedule > MTL for at least 8 time blocks in Peak hours are eligible for MTL support.
- 3) SCED_MTL support is contingent upon the following actions by the generating station -
 - a) Report eligibility to NLDC/RLDCs by 1530 hrs of D-1 and
 - b) Furnish standard declaration Format-A1 by 2000 hrs of D-1 to RLDCs/NLDC and
 - c) Participation in SCED
- 4) CERC Approved Detailed procedure for moderating schedule up to minimum turndown level for Section 62 generators through SCED is available at the below link.

https://cercind.gov.in/regulations/ProcedureL_1_265_2022_CERC_GRID_CODE.pdf