

S.No.	Plant Name	Min Schedule (MW)	Max MTL (MW)	SCED_MTL
1	Kudgi-1	300.00	1239.70	Yes
2	Mauda	392.05	518.38	Yes
3	Mauda 2	517.74	684.25	Yes
4	NTPL	279.23	521.12	Yes
5	Dadri Stage 1	158.38	422.73	Yes
6	Unchahar TPS 2	148.59	208.36	Yes

Notes:

1) List of power plants with Schedule < Minimum Turndown Level (MTL) are shown in the above table. Power plants that have already received SCUC =yes for the next day are excluded from this list.

2) Power plants with Schedule < MTL during any time block in Off-Peak hours AND Schedule \geq MTL for atleast 8 time blocks in Peak hours are eligible for MTL support.

3) SCED_MTL support is contingent upon the following actions by the generating station-

- a) Report eligibility to NLDC/RLDCs by 1530 hrs of D-1 and
- b) Furnish standard declaration Format-A1 by 2000 hrs of D-1 to RLDCs/NLDC and
- c) Participation in SCED

4) CERC Approved Detailed procedure for moderating schedule up to minimum turndown level for Section 62 generators through SCED is available at the below link.

https://cercind.gov.in/regulations/ProcedureL_1_265_2022_CERC_GRID_CODE.pdf