




POWER SYSTEM OPERATION CORPORATION LIMITED
 NATIONAL LOAD DESPATCH CENTRE NEW DELHI

RIHAND:Frequency

National Grid Frequency Profile for

06-Nov-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.39	5.20	19.91	39.26	27.22	6.67	1.35	25.50	56.03	18.47	10.84	98.25	21.35

Average Frequency	49.96	Frequency Variation Index :	0.113	Standard Deviation :	0.100
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.24	16:06:10	Max	50.200	22:00:00
Min	49.63	17:28:00	Min	49.760	17:30:00