




POWER SYSTEM OPERATION CORPORATION LIMITED

NATIONAL LOAD DESPATCH CENTRE NEW DELHI

National Grid Frequency Profile for

07-Nov-14

NTPC-VINDHYACHAL:Frequency



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	1.83	7.23	22.80	29.83	28.70	8.66	0.95	31.86	46.57	21.56	11.98	97.22	20.83

Average Frequency	49.96	Frequency Variation Index :	0.148	Standard Deviation :	0.114
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.27	21:57:10	Max	50.211	22:00:00
Min	49.64	6:21:10	Min	49.706	6:30:00