




**POWER SYSTEM OPERATION CORPORATION LIMITED**  
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

16-Jul-16



<49.2	<49.7	<49.90	<49.97	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	49.90-50.05	49.7-50.2	49.97-50.03	50.05-50.1	>50	>50.03	>50.05	>50.2
0	0.00	1.79	17.55	0.00	1.79	31.26	58.53	8.41	65.31	100.00	35.35	24.58	66.90	47.11	32.89	0.00

<b>Average Frequency</b>	<b>50.02</b>	<b>Frequency Variation Index :</b>	<b>0.037</b>	<b>Standard Deviation :</b>	<b>0.056</b>
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency	
Max	50.19 8:04:00
Min	49.84 18:13:40

15 minute average Frequency		
Max	50.122	8:15:00
Min	49.921	0:45:00

No. of excursion above 50.03 Hz	161
No. of excursion below 49.97 Hz	110
No. of excursion above 50.00 Hz	150
No. of excursion below 50.00 Hz	151

Average time freq remains below 49.97 per excursion	0:02:18	Average time frequency remains above 50.03 per excursion	0:04:13
---	---------	--	---------