




POWER SYSTEM OPERATION CORPORATION LIMITED

NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

16-Nov-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	0.22	1.01	22.14	48.82	21.11	6.70	1.23	46.45	52.33	24.63	93.30	25.93

Average Frequency	50.06	Frequency Variation Index :	0.119	Standard Deviation :	0.089
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.42	6:04:00	Max	50.313	0:00:00
Min	49.72	22:08:00	Min	49.942	12:30:00