




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

17-Aug-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	3.21	7.40	21.30	40.02	22.78	4.65	0.64	31.92	55.56	12.52	7.26	96.15	22.58

Average Frequency		49.94	Frequency Variation Index :		0.158	Standard Deviation :		0.109
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.23	6:04:10	Max	50.149	14:15:00
Min	49.53	19:12:40	Min	49.652	19:30:00

