




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

20-Aug-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	11.33	23.99	32.08	25.49	6.67	0.44	0.00	67.40	30.72	1.88	1.44	88.67	8.46

Average Frequency		49.84	Frequency Variation Index :		0.374	Standard Deviation :		0.111
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.155	6:03:40	Max	50.001	6:15:00
Min	49.49	20:37:50	Min	49.600	20:45:00

