




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

24-Aug-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	3.00	14.64	22.16	34.90	21.16	3.26	0.88	39.80	47.56	12.64	8.58	96.12	16.32

Average Frequency	49.92	Frequency Variation Index :	0.201	Standard Deviation :	0.116
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.309	17:03:40	Max	50.187	17:15:00
Min	49.61	4:50:30	Min	49.698	5:30:00

