




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

26-Aug-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	2.57	13.76	36.03	30.53	15.41	1.02	0.68	52.36	41.24	6.40	4.71	96.75	13.62

Average Frequency	49.90	Frequency Variation Index :	0.211	Standard Deviation :	0.103
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.34	13:02:30	Max	50.141	13:15:00
Min	49.61	0:10:30	Min	49.690	9:30:00

