




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

26-Nov-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	0.96	7.47	27.38	42.09	19.84	2.26	8.43	50.05	41.53	19.50	97.74	24.29

Average Frequency	50.03	Frequency Variation Index :	0.088	Standard Deviation :	0.089
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.31	17:02:50	Max	50.175	14:15:00
Min	49.73	17:42:20	Min	49.808	16:30:00

