




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

National Grid Frequency Profile for

27-Aug-14

SRIPERUMBUDUR:Frequency



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	2.64	11.05	29.12	34.44	21.54	1.19	0.01	42.81	50.01	7.18	6.02	97.35	21.08

Average Frequency		49.91	Frequency Variation Index :	0.178	Standard Deviation :	0.102
--------------------------	--	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.201	6:04:40	Max	50.055	6:15:00
Min	49.57	19:03:30	Min	49.680	15:45:00

