




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

27-Nov-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.32	0.94	10.32	28.52	41.22	17.20	1.48	11.59	50.01	38.40	19.77	98.19	23.24

Average Frequency		50.02	Frequency Variation Index :		0.091	Standard Deviation :		0.094
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.26	13:03:40	Max	50.190	13:15:00
Min	49.58	17:40:30	Min	49.748	17:45:00