




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

29-Aug-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	1.03	6.17	23.77	37.40	27.62	4.02	0.00	30.97	54.78	14.25	10.28	98.97	22.59

Average Frequency	49.95	Frequency Variation Index :	0.125	Standard Deviation :	0.098
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.18	10:03:50	Max	50.107	15:15:00
Min	49.62	4:14:20	Min	49.712	4:30:00

