

Format-2: NLDC SCUC for Date 'D': 08/Aug/2024 (Published on D-1 basis: 07/Aug/2024) at 1800 hrs

S.No.	Generator Name	Time Blocks	Schedule MW	ECR(paise/kWh)	SCUCYN
1	Dadri Stage 1	49-61	260.49	461.5	NO
2	Anta_LF	1-96	2.61	1753	NO
3	Anta_RF	1-96	5.19	1346.5	YES <small>(for 77-96 blocks)</small>
4	Auraiya_RF	1-96	12.83	1258	YES <small>(for 77-96 blocks)</small>
5	Dadri_RF	1-96	12.72	1243.7	YES <small>(for 77-96 blocks)</small>
6	Gadarwara-1	38-66	241.48	325.7	YES
7	NTPC-KHARGONE	16-24, 36-72	184.96	400.2	YES
8	Gandhar-ComGas	1-96	0.27	1386.1	NO
9	RGPPL-RLNG	1-96	0	1179	YES <small>(for 77-96 blocks)</small>
10	Ramagundam TPS Stage 1&2	47-57	666.8	413.1	NO
11	Simhadri -NTPC Stage -1	49-59	436.89	354.2	NO
12	Kudgi-1	37-74	343.63	492.5	YES
13	Kawas-ComGas	1-96	0.22	1373	NO
14	Barh	38-65	664.36	283.6	YES
15	Kahalgaon Stage 2	1	593.04	233.3	YES
16	Farakka Stage 1 and 2	33-66	342.6	311.1	YES
17	FARAKKA-STAGE-3	21-23, 33-69	53.47	305	YES
18	Barh 1	48-62	302.22	283.6	YES
19	TelanganaSTPP	37-68	195.39	379.1	YES

Plants and Time Blocks with Schedule less than minimum turndown level are indicated.

Lowest value of the Schedule in the time blocks is provided in the table.