

S.No.	Generator Name	Time Blocks	Schedule MW	ECR(paise/kWh)	SCUCYN
1	Dadri Stage 2	2-69, 77-96	498.41	473.5	YES
2	Dadri Stage 1	1-96	236.39	525.7	YES
3	Anta_RF	66-96	0	1207.8	YES (*For 66-80 blocks)
4	Auraiya_RF	66-96	0	1228	YES (*For 66-80 blocks)
5	Dadri_LF	1-96	0	2388.2	NO
6	Dadri_RF	66-96	10.49	1170	YES (*For 66-80 blocks)
7	NTPC SOLAPUR	38-64	547.8	473	YES
8	Gadarwara-1	10-23, 44-59, 86-87	709.08	366	YES
9	NTPC-KHARGONE	1-26, 40-61, 84-96	516.16	405.4	YES
10	Gandhar-RLNG	66-96	0	1049.9	YES (*For 66-80 blocks)
11	Kawas-RLNG	1-24	0	1055	NO
12	RGPPL-RLNG	1-96	0	1201	NO
13	Ramagundam TPS Stage 1&2	45-59	886.11	393.5	NO
14	Simhadri -NTPC Stage -1	50-58	216.14	378.5	NO
15	Simhadri NTPC Stage 2	48-56	497.35	373.9	NO
16	NTPL	46-57	493.24	443.7	NO
17	Kudgi-1	3-21, 35-67	350.35	497.3	YES
18	Kawas-ComGas	66-96	0	1277	YES (*For 66-80 blocks)
19	Farakka Stage 1 and 2	10-21, 35-61	460.69	335.9	YES
20	FARAKKA-STAGE-3	9-21, 37-61	198.22	325.5	YES
21	TelanganaSTPP	9-21, 48-60	195.33	348.1	YES
22	LKPLPHASE2_RLNG	1-96	0	1176	YES (*For 66-80 blocks)

Plants and Time Blocks with Schedule less than minimum turndown level are indicated.

Lowest value of the Schedule in the time blocks is provided in the table

The time blocks provided for open cycle operation at gas plants are tentative. Actual operation may vary based on real-time grid conditions