

S.No.	Generator Name	Time Blocks	Schedule MW	ECR(paise/kWh)	SCUCYN
1	Dadri Stage 2	1-30, 40-64, 78-96	325.1	473.5	YES
2	Dadri Stage 1	1-27, 42-67, 80-96	163.79	525.7	YES
3	Anta_RF	1-96	6.22	1207.8	NO
4	Auraiya_RF	1-96	0	1228	NO
5	Dadri_LF	1-96	0	2388.2	NO
6	Gadarwara-1	2-23, 50-57, 84-89	709.08	366	YES
7	NTPC-KHARGONE	1-26, 48-59, 83-96	451.59	405.4	YES
8	Gandhar-RLNG	1-96	0	1049.9	NO
9	Kawas-RLNG	1-24	0	1055	NO
10	RGPPL-RLNG	1-96	0	1201	NO
11	Simhadri -NTPC Stage -1	1-21, 50-59	216.14	378.5	NO
12	Vellur NTECL	1	764.11	325.1	NO
13	Kudgi-1	1-22, 45-63, 91-96	350.35	497.3	YES
14	Kawas-ComGas	25-96	0	1277	NO
15	Farakka Stage 1 and 2	1-26, 44-65, 82-96	295.7	335.9	YES
16	FARAKKA-STAGE-3	1-25, 45-64, 87-96	198.22	325.5	YES
17	TelanganaSTPP	1-24, 46-62, 92-96	213.25	348.1	YES
18	LKPLPHASE2_RLNG	1-96	0	1800	NO

Plants and Time Blocks with Schedule less than minimum turndown level are indicated.

Lowest value of the Schedule in the time blocks is provided in the table.

The time blocks provided for open cycle operation at gas plants are tentative. Actual operation may vary based on real-time grid conditions