

S.No.	Generator Name	Time Blocks	Schedule MW	ECR(paise/kWh)	SCUCYN
1	Dadri Stage 2	1-19, 51-59	500.75	430.9	NO
2	Dadri Stage 1	1-26, 46-68, 82-96	240.65	492.4	YES
3	Anta_RF	1-96	0	1168.1	NO
4	Auraiya_RF	1-96	0	1188	NO
5	Dadri_LF	1-96	0	2388.2	NO
6	Dadri_RF	1-96	0	1131.4	NO
7	NTPC SOLAPUR	1-21, 48-61, 85-96	448.04	435.2	YES
8	Gadarwara-1	3-21	541.69	331.4	YES
9	NTPC-KHARGONE	1-25, 53-57, 88-91, 94-96	444.89	390.2	YES
10	Gandhar-RLNG	1-96	0	1014	NO
11	Kawas-RLNG	1-96	0	1019	NO
12	RGPPL-RLNG	1-96	0	1284	NO
13	Simhadri -NTPC Stage -1	11-18	434.59	365.8	NO
14	NTPL	2-16	243.67	429.3	NO
15	Kudgi-1	1-22, 49-59, 89-96	718.47	450.3	NO
16	Farakka Stage 1 and 2	1-22, 94-96	535.18	338.8	YES
17	FARAKKA-STAGE-3	1-24, 92-96	198.22	332	YES
18	TelanganaSTPP	1-21, 53-63, 94-96	211.44	371.9	YES
19	LKPLPHASE2_RLNG	1-96	0	2400	NO

Plants and Time Blocks with Schedule less than minimum turndown level are indicated.

Lowest value of the Schedule in the time blocks is provided in the table.

# The time blocks provided for open cycle operation at gas plants are tentative. Actual operation may vary based on real-time grid conditions