

Format-2: NLDC SCUC for Date 'D': 25/Feb/2025 (Published on D-1 basis: 24/Feb/2025) at 1500 hrs

S.No.	Generator Name	Time Blocks	Schedule MW	ECR(paise/kWh)	SCUCYN
1	Dadri Stage 2	1-24, 42-68, 85-96	364.59	429	YES
2	Dadri Stage 1	1-26, 46-68, 86-96	154.55	481.8	YES
3	Tanda-2	6-24, 43-72, 87-96	625.52	341.5	YES
4	Anta_RF	30-48	0	1186.1	YES #(For 30-48 time blocks)
5	Auraiya_RF	30-48	0	1206	YES #(For 30-48 time blocks)
6	Dadri_RF	30-48	14.34	1153.2	YES #(For 30-48 time blocks)
7	NTPC SOLAPUR	1-18, 47-64, 84-96	445.89	440.5	YES
8	NTPC-KHARGONE	45-65, 88-90	401.19	403	YES
9	Gandhar-RLNG	30-48	0	1030	YES #(For 30-48 time blocks)
10	Kawas-RLNG	30-48	0	1035	YES #(For 30-48 time blocks)
11	RGPPL-RLNG	1-96	0	1207	NO
12	Barh	44-67	173.23	302.7	YES
13	Farakka Stage 1 and 2	1-22, 44-65, 90-96	530.9	341.4	YES
14	FARAKKA-STAGE-3	7-20, 46-64, 94-96	201.68	324.2	YES
15	Barh 1	44-64	488.65	304.3	YES
16	AGTPP Agartala	1-20	33.69	444.1	YES
17	LKPLPHASE2_RLNG	1-96	0	1600	NO

Plants and Time Blocks with Schedule less than minimum turndown level are indicated.

Lowest value of the Schedule in the time blocks is provided in the table.

The time blocks provided for open cycle operation at gas plants are tentative. Actual operation may vary based on real-time grid conditions