

S.No.	Generator Name	Time Blocks	Schedule MW	ECR(paise/kWh)	SCUCYN
1	Unchahar TPS 1	2-14, 45-54	181.26	367	YES
2	Dadri Stage 2	1-23, 37-72	494.57	402.7	YES
3	Dadri Stage 1	1-26, 45-68, 92-96	142.27	472.4	YES
4	Anta_RF	1-96	0	1388.1	NO
5	Auraiya_RF	1-96	0	1434	NO
6	Dadri_RF	1-96	0	1365.4	NO
7	NTPC SOLAPUR	1-26, 33-66, 80-81, 93-96	372.08	438.2	YES
8	Gadarwara-1	46-71	562.38	298.2	YES
9	NTPC-KHARGONE	1-75	197.1	398.2	YES
10	Gandhar-RLNG	1-96	0	1204.2	NO
11	Kawas-RLNG	1-96	0	1214	NO
12	RGPP-RLNG	1-96	0	1302	NO
13	Ramagundam TPS Stage 3	50-60	246.34	370.3	NO
14	Simhadri -NTPC Stage -1	55-59	434.59	371.3	NO
15	NTPL	40-63	301.12	416.7	NO
16	Kudgi-1	8-20, 45-62	587.38	439.4	NO
17	Farakka Stage 1 and 2	1-22, 32-72	413.69	330.5	YES
18	FARAKKA-STAGE-3	1-3, 6-21, 33-70	110.33	319.5	YES
19	AGBPP Kathalguri	9-22	120.0	505.1	NO
20	TelanganaSTPP	52-63	215.47	341.4	NO
21	LKPLPHASE2_RLNG	1-96	0	1800	NO

Plants and Time Blocks with Schedule less than minimum turndown level are indicated.

Lowest value of the Schedule in the time blocks is provided in the table.

The time blocks provided for open cycle operation at gas plants are tentative. Actual operation may vary based on real-time grid conditions