

S.No.	Generator Name	Time Blocks	Schedule MW	ECR(paise/kWh)	SCUCYN
1	Unchahar TPS 1	45-57	88.87	367	YES
2	Dadri Stage 2	51-64	467.41	402.7	YES
3	Dadri Stage 1	1-3, 6-21, 47-70	101.71	472.4	YES
4	Anta_RF	1-96	0	1388.1	NO
5	Auraiya_RF	1-96	0	1434	NO
6	Dadri_RF	1-96	0	1365.4	NO
7	Mauda	49-55	399.87	341.2	YES
8	Mauda 2	50-55	276.38	342.6	YES
9	NTPC SOLAPUR	2-20, 36-68, 82-96	466.65	438.2	YES
10	NTPC-KHARGONE	40-71	417.84	398.2	YES
11	Gandhar-RLNG	1-96	0	1204.2	NO
12	Kawas-RLNG	1-96	0	1214	NO
13	RGPPL-RLNG	1-96	0	1302	NO
14	NTPL	1	492.39	416.7	YES
15	Kudgi-1	1, 47-61	924.54	439.4	YES
16	Barh	40-65	167.71	297	YES
17	Farakka Stage 1 and 2	36-71	433.34	330.5	YES
18	FARAKKA-STAGE-3	36-71	113.79	319.5	YES
19	Barh 1	51-56	567.8	299.6	YES
20	LKPLPHASE2_RLNG	1-96	0	1800	NO

Plants and Time Blocks with Schedule less than minimum turndown level are indicated.

Lowest value of the Schedule in the time blocks is provided in the table.

The time blocks provided for open cycle operation at gas plants are tentative. Actual operation may vary based on real-time grid conditions