

S.No.	Generator Name	Time Blocks	Schedule MW	ECR(paise/kWh)	SCUCYN
1	UNCHAHAR 4	44-64	222.45	350.6	YES
2	Unchahar TPS 1	41-67	99.2	367	YES
3	Unchahar TPS 3	44-64	100.75	356.7	YES
4	Dadri Stage 2	41-68	380.33	402.7	YES
5	Dadri Stage 1	47-67	122.27	472.4	NO
6	Anta_RF	1-96	0	1388.1	NO
7	Auraiya_RF	1-96	0	1434	NO
8	Dadri_RF	1-96	0	1365.4	NO
9	NTPC SOLAPUR	1-6, 12-20, 36-70, 83-96	393.65	438.2	YES
10	NTPC-KHARGONE	40-69	417.84	398.2	YES
11	Gandhar-RLNG	1-96	0	1204.2	NO
12	Kawas-RLNG	1-96	152.28	1214	NO
13	RGPPPL-RLNG	1-96	0	1302	NO
14	NTPL	53-55	397.3	416.7	NO
15	Kudgi-1	46-60	587.38	439.4	NO
16	Barh	36-67	137.74	297	YES
17	Farakka Stage 1 and 2	33-67	293.58	330.5	YES
18	FARAKKA-STAGE-3	36, 40-64	110.33	319.5	YES
19	Barh 1	42-65	337.35	299.6	YES
20	AGBPP Kathalguri	9-20, 43-66	125.02	505.1	YES
21	LKPLPHASE2_RLNG	1-96	0	1800	NO

*Plants and Time Blocks with Schedule less than minimum turndown level are indicated.*

*Lowest value of the Schedule in the time blocks is provided in the table.*

*# The time blocks provided for open cycle operation at gas plants are tentative. Actual operation may vary based on real-time grid conditions*