

S.No.	Generator Name	Time Blocks	Schedule MW	ECR(paise/kWh)	SCUCYN
1	UNCHAHAR 4	42-68	217.21	350.6	YES
2	Unchahar TPS 1	41-60	180.48	367	YES
3	Unchahar TPS 3	42-68	100.75	356.7	YES
4	Dadri Stage 2	5-17, 41-72	380.33	402.7	YES
5	Dadri Stage 1	43-65	122.27	472.4	NO
6	Anta_RF	1-96	0	1388.1	NO
7	Auraiya_RF	1-96	0	1434	NO
8	Dadri_RF	1-96	0	1365.4	NO
9	NTPC SOLAPUR	36-65	384.65	438.2	YES
10	Gadarwara-1	44-67	281.19	298.2	YES
11	NTPC-KHARGONE	1-20, 35-73, 96	309.22	398.2	YES
12	Gandhar-RLNG	1-96	0	1204.2	NO
13	Kawas-RLNG	1-96	0	1214	NO
14	RGPPPL-RLNG	1-96	0	1302	NO
15	Simhadri -NTPC Stage -1	54-58	434.59	371.3	NO
16	Kudgi-1	43-62	488.77	439.4	NO
17	Barh	36-69	126.64	297	YES
18	Farakka Stage 1 and 2	33-70	459.94	330.5	YES
19	FARAKKA-STAGE-3	29, 33-67	110.33	319.5	YES
20	Barh 1	42-65	168.68	299.6	YES
21	AGBPP Kathalguri	1-3, 5-20, 41-66, 69-72	93.58	505.1	YES
22	AGTPP Agartala	2, 5-20	29.24	447.4	YES
23	TelanganaSTPP	55-59	475.0	341.4	NO
24	LKPLPHASE2_RLNG	1-96	0	1604.24	NO

Plants and Time Blocks with Schedule less than minimum turndown level are indicated.

Lowest value of the Schedule in the time blocks is provided in the table.

The time blocks provided for open cycle operation at gas plants are tentative. Actual operation may vary based on real-time grid conditions