

POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE
NEW DELHI

Date of Reporting: **3-Jan-20**
System Reliability Indices Report for: **2-Jan-20**

Percentage (%) of times ATC was violated

S.No.	Corridor	Number of Blocks Violated	Number of Hours Violated	%Violation
1	WR-NR	0	0.00	0.00
2	ER-NR	2	0.50	2.08
3	Import of NR	0	0.00	0.00
4	NEW-SR	6	1.50	6.25
5	NER Import	0	0.00	0.00

Percentage(%) of times (N-1) Criteria was violated

S.No.	Corridor	Number of Blocks Violated	Number of Hours Violated	%Violation
1	WR-NR	0	0.00	0.00
2	ER-NR	0	0.00	0.00
3	Import of NR	0	0.00	0.00
4	NEW-SR	0	0.00	0.00
4	NER Import	0	0.00	0.00

Voltage Profile for the day of 02-Jan-2020

Region	Station	%age of time Voltage below 728/380 kV	%age of time Voltage between 728/380 kV & 800/420 kV	%age of time Voltage above 800/420 kV	Voltage deviation index (%age of time voltage is outside IEGC band)
NR	Agra	0.00%	100.00%	0.00%	0.00%
	Agra (Fatehabad)	0.00%	97.85%	2.15%	2.15%
	Anpara-C	0.00%	100.00%	0.00%	0.00%
	Anpara-D	0.00%	100.00%	0.00%	0.00%
	Anta	0.00%	100.00%	0.00%	0.00%
	Ballia	0.00%	100.00%	0.00%	0.00%
	Bara	0.00%	100.00%	0.00%	0.00%
	Bhiwani	0.00%	100.00%	0.00%	0.00%
	Fatehpur	0.00%	100.00%	0.00%	0.00%
	Jhatikara	0.00%	100.00%	0.00%	0.00%
	Kanpur GIS	0.00%	100.00%	0.00%	0.00%
	Lucknow	0.00%	85.69%	14.31%	14.31%
	Lalitpur	0.00%	100.00%	0.00%	0.00%
	Meerut	0.00%	91.46%	8.54%	8.54%
Phagi	0.00%	100.00%	0.00%	0.00%	
Varanasi	0.00%	100.00%	0.00%	0.00%	
WR	Akola	0.00%	100.00%	0.00%	0.00%
	Aurangabad	0.00%	100.00%	0.00%	0.00%
	Bhopal (BDTCL)	0.00%	100.00%	0.00%	0.00%
	Bilaspur	0.00%	100.00%	0.00%	0.00%
	Bina	0.00%	100.00%	0.00%	0.00%
	Champa	0.00%	100.00%	0.00%	0.00%
	Gwalior	0.00%	100.00%	0.00%	0.00%
	Indore	0.00%	100.00%	0.00%	0.00%
	Koradi	0.00%	100.00%	0.00%	0.00%
	Pune	0.00%	100.00%	0.00%	0.00%
	Raigarh Pooling	0.00%	100.00%	0.00%	0.00%
	Sasan	0.00%	100.00%	0.00%	0.00%
	Satna	0.00%	100.00%	0.00%	0.00%
	Seoni	0.00%	100.00%	0.00%	0.00%
	Sipat	0.00%	100.00%	0.00%	0.00%
	Solapur	0.00%	98.47%	1.53%	1.53%
	Tamnar	0.00%	100.00%	0.00%	0.00%
	Tirora	0.00%	100.00%	0.00%	0.00%
Vadodara	0.00%	100.00%	0.00%	0.00%	
Vindhyachal PS	0.00%	100.00%	0.00%	0.00%	
Wardha	0.00%	100.00%	0.00%	0.00%	
SR	Kurnool	0.00%	100.00%	0.00%	0.00%
	Nellore PS	0.00%	100.00%	0.00%	0.00%
	Raichur	0.00%	100.00%	0.00%	0.00%
	Nizamabad	0.00%	95.63%	4.38%	4.38%
	Srikakulam	0.00%	100.00%	0.00%	0.00%
	Thiruvalam	0.00%	100.00%	0.00%	0.00%
Vemagiri	0.00%	100.00%	0.00%	0.00%	
ER	Angul	0.00%	100.00%	0.00%	0.00%
	Gaya	0.00%	100.00%	0.00%	0.00%
	Jharsuguda	0.00%	100.00%	0.00%	0.00%
	Ranchi	0.00%	100.00%	0.00%	0.00%
NER	Balipara (400 kV)	0.00%	100.00%	0.00%	0.00%
	Bongaigaon (400 kV)	0.00%	100.00%	0.00%	0.00%
	Palatana (400 kV)	0.00%	100.00%	0.00%	0.00%
	Misa (400 kV)	0.00%	100.00%	0.00%	0.00%
	Biswanath Chariali (400 kV)	0.00%	100.00%	0.00%	0.00%
Silchar (400 kV)	0.00%	100.00%	0.00%	0.00%	

Remarks: Unless otherwise specified, station may be treated as 765kV S/S.