

**POWER SYSTEM OPERATION CORPORATION LIMITED**  
**NATIONAL LOAD DESPATCH CENTRE**  
**NEW DELHI**

Date of Reporting: **6-Aug-20**  
System Reliability Indices Report for: **5-Aug-20**

**Percentage (%) of times ATC was violated**

| <b>S.No.</b> | <b>Corridor</b> | <b>Number of Blocks Violated</b> | <b>Number of Hours Violated</b> | <b>%Violation</b> |
|--------------|-----------------|----------------------------------|---------------------------------|-------------------|
| 1            | WR-NR           | 0                                | 0.00                            | 0.00              |
| 2            | ER-NR           | 2                                | 0.50                            | 2.08              |
| 3            | Import of NR    | 0                                | 0.00                            | 0.00              |
| 4            | NEW-SR          | 0                                | 0.00                            | 0.00              |
| 5            | NER Import      | 0                                | 0.00                            | 0.00              |

**Percentage(%) of times (N-1) Criteria was violated**

|   |              |   |      |      |
|---|--------------|---|------|------|
| 1 | WR-NR        | 0 | 0.00 | 0.00 |
| 2 | ER-NR        | 0 | 0.00 | 0.00 |
| 3 | Import of NR | 0 | 0.00 | 0.00 |
| 4 | NEW-SR       | 0 | 0.00 | 0.00 |
| 4 | NER Import   | 0 | 0.00 | 0.00 |

### Voltage Profile for the day of 05-Aug-2020

| Region           | Station                     | %age of time Voltage below 728/380 kV | %age of time Voltage between 728/380 kV & 800/420 kV | %age of time Voltage above 800/420 kV | Voltage deviation index (%age of time voltage is outside IEGC band) |
|------------------|-----------------------------|---------------------------------------|--|---------------------------------------|---|
| NR               | Agra                        | 0.00%                                 | 99.72%   | 0.28%                                 | 0.28%   |
|                  | Anpara-D                    | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Anta                        | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Ballia                      | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Bara                        | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Bhiwani                     | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Bareilly                    | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Jhatikara                   | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Kanpur GIS                  | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Lucknow                     | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Lalitpur                    | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Meerut                      | 0.00%                                 | 99.17%   | 0.83%                                 | 0.83%   |
|                  | Moga                        | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Phagi                       | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
| Varanasi         | 0.00%                       | 100.00%                               | 0.00%  | 0.00%                                 |   |
| WR               | Akola                       | 0.00%                                 | 99.10%   | 0.90%                                 | 0.90%   |
|                  | Aurangabad                  | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Bhopal (BDTCL)              | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Bilaspur                    | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Bina                        | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Champa                      | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Dhule (BDTCL)               | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Ektuni                      | 0.00%                                 | 93.61%   | 6.39%                                 | 6.39%   |
|                  | Gwalior                     | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Indore                      | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Jabalpur                    | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Koradi                      | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Pune                        | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Raigarh Pooling             | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Sasan                       | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Satna                       | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Seoni                       | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Sipat                       | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Solapur                     | 0.00%                                 | 99.65%   | 0.35%                                 | 0.35%   |
|                  | Tamnar                      | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
| Tirora           | 0.00%                       | 100.00%                               | 0.00%  | 0.00%                                 |   |
| Vadodara         | 0.00%                       | 100.00%                               | 0.00%  | 0.00%                                 |   |
| Vindhyachal PS   | 0.00%                       | 100.00%                               | 0.00%  | 0.00%                                 |   |
| Wardha           | 0.00%                       | 100.00%                               | 0.00%  | 0.00%                                 |   |
| SR               | Kurnool                     | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Nellore PS                  | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Raichur                     | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Nizamabad                   | 0.00%                                 | 85.35%   | 14.65%                                | 14.65%  |
|                  | Srikakulam                  | 0.00%                                 | 94.79%   | 5.21%                                 | 5.21%   |
|                  | Thiruvalam                  | 0.00%                                 | 94.79%   | 5.21%                                 | 5.21%   |
| Vemagiri         | 0.00%                       | 100.00%                               | 0.00%  | 0.00%                                 |   |
| ER               | Angul                       | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Gaya                        | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Jharsuguda                  | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Ranchi                      | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
| Sasaram          | 0.00%                       | 100.00%                               | 0.00%  | 0.00%                                 |   |
| NER              | Azara (400 kV)              | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Bongaigaon (400 kV)         | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Bongaigaon TPS (400 kV)     | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Byrnihat (400 kV)           | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Palatana (400 kV)           | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Misa (400 kV)               | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Ranganadi (400 kV)          | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
|                  | Biswanath Chariali (400 kV) | 0.00%                                 | 100.00%  | 0.00%                                 | 0.00%   |
| Silchar (400 kV) | 0.00%                       | 100.00%                               | 0.00%  | 0.00%                                 |   |

Remarks: Unless otherwise specified, station may be treated as 765kV S/S.