

**POWER SYSTEM OPERATION CORPORATION LIMITED**  
**NATIONAL LOAD DESPATCH CENTRE**  
**NEW DELHI**

Date of Reporting: **7-Oct-19**  
System Reliability Indices Report for: **6-Oct-19**

1	WR-NR	0	0.00	0.00
2	ER-NR	0	0.00	0.00
3	Import of NR	0	0.00	0.00
4	NEW-SR	0	0.00	0.00
5	NER Import	0	0.00	0.00

**Percentage(%) of times (N-1) Criteria was violated**

S.No.	Corridor	Number of Blocks Violated	Number of Hours Violated	%Violation
1	WR-NR	0	0.00	0.00
2	ER-NR	0	0.00	0.00
3	Import of NR	0	0.00	0.00
4	NEW-SR	0	0.00	0.00
4	NER Import	0	0.00	0.00

## Voltage Profile for the day of 06-Oct-2019

Region	Station	%age of time Voltage below 728/380 kV	%age of time Voltage between 728/380 kV & 800/420 kV	%age of time Voltage above 800/420 kV	Voltage deviation index (%age of time voltage is outside IEGC band)
NR	Agra	0.00%	100.00%	0.00%	0.00%
	Agra (Fatehabad)	0.00%	100.00%	0.00%	0.00%
	Anpara-C	0.00%	100.00%	0.00%	0.00%
	Anpara-D	0.00%	100.00%	0.00%	0.00%
	Anta	0.00%	100.00%	0.00%	0.00%
	Ballia	0.00%	100.00%	0.00%	0.00%
	Bhiwani	0.00%	100.00%	0.00%	0.00%
	Fatehpur	0.00%	100.00%	0.00%	0.00%
	Greater Noida	0.00%	98.82%	1.18%	1.18%
	Jhatikara	0.00%	100.00%	0.00%	0.00%
	Kanpur GIS	0.00%	100.00%	0.00%	0.00%
	Lucknow	0.00%	100.00%	0.00%	0.00%
	Lalitpur	0.00%	100.00%	0.00%	0.00%
	Meerut	0.00%	100.00%	0.00%	0.00%
	Moga	0.00%	100.00%	0.00%	0.00%
WR	Phagi	0.00%	100.00%	0.00%	0.00%
	Varanasi	0.00%	100.00%	0.00%	0.00%
	Unnao	0.00%	100.00%	0.00%	0.00%
	Akola	0.00%	100.00%	0.00%	0.00%
	Aurangabad	0.00%	100.00%	0.00%	0.00%
	Bhopal (BDTCL)	0.00%	100.00%	0.00%	0.00%
	Bilaspur	0.00%	100.00%	0.00%	0.00%
	Bina	0.00%	100.00%	0.00%	0.00%
	Champa	0.00%	100.00%	0.00%	0.00%
	Gwalior	0.00%	100.00%	0.00%	0.00%
	Indore	0.00%	100.00%	0.00%	0.00%
	Jabalpur	0.00%	100.00%	0.00%	0.00%
	Koradi	0.00%	100.00%	0.00%	0.00%
	Pune	0.00%	100.00%	0.00%	0.00%
	Raigarh Pooling	0.00%	100.00%	0.00%	0.00%
Sasan	0.00%	100.00%	0.00%	0.00%	
Satna	0.00%	100.00%	0.00%	0.00%	
Seoni	0.00%	100.00%	0.00%	0.00%	
Sipat	0.00%	100.00%	0.00%	0.00%	
Solapur	0.00%	83.26%	16.74%	16.74%	
Tamnar	0.00%	100.00%	0.00%	0.00%	
Tirora	0.00%	100.00%	0.00%	0.00%	
Vadodara	0.00%	100.00%	0.00%	0.00%	
Vindhyachal PS	0.00%	100.00%	0.00%	0.00%	
Wardha	0.00%	100.00%	0.00%	0.00%	
SR	Kurnool	0.00%	100.00%	0.00%	0.00%
	Nellore PS	0.00%	100.00%	0.00%	0.00%
	Raichur	0.00%	100.00%	0.00%	0.00%
	Nizamabad	0.00%	100.00%	0.00%	0.00%
	Srikakulam	0.00%	100.00%	0.00%	0.00%
	Thiruvalam	0.00%	100.00%	0.00%	0.00%
ER	Vemagiri	0.00%	100.00%	0.00%	0.00%
	Angul	0.00%	100.00%	0.00%	0.00%
	Gaya	0.00%	100.00%	0.00%	0.00%
	Jharsuguda	0.00%	100.00%	0.00%	0.00%
	Ranchi	0.00%	100.00%	0.00%	0.00%
NER	Sasaram	0.00%	100.00%	0.00%	0.00%
	Azara (400 kV)	0.00%	100.00%	0.00%	0.00%
	Bongaigaon (400 kV)	0.00%	100.00%	0.00%	0.00%
	Bongaigaon TPS (400 kV)	0.00%	100.00%	0.00%	0.00%
	Byrnihat (400 kV)	0.00%	100.00%	0.00%	0.00%
	Palatana (400 kV)	0.00%	100.00%	0.00%	0.00%
	Misa (400 kV)	0.00%	100.00%	0.00%	0.00%
	Ranganadi (400 kV)	0.00%	99.31%	0.69%	0.69%
	Biswanath Chariali (400 kV)	0.00%	100.00%	0.00%	0.00%
Silchar (400 kV)	0.00%	100.00%	0.00%	0.00%	

Remarks: Unless otherwise specified, station may be treated as 765kV S/S.