

**POWER SYSTEM OPERATION CORPORATION LIMITED**  
**NATIONAL LOAD DESPATCH CENTRE**  
**NEW DELHI**

Date of Reporting: 21-Feb-20  
System Reliability Indices Report for: 20-Feb-20

**Percentage (%) of times ATC was violated**

S.No.	Corridor	Number of Blocks Violated	Number of Hours Violated	%Violation
1	WR-NR	0	0.00	0.00
2	ER-NR	0	0.00	0.00
3	Import of NR	0	0.00	0.00
4	NEW-SR	0	0.00	0.00
5	NER Import	0	0.00	0.00

**Percentage(%) of times (N-1) Criteria was violated**

S.No.	Corridor	Number of Blocks Violated	Number of Hours Violated	%Violation
1	WR-NR	0	0.00	0.00
2	ER-NR	0	0.00	0.00
3	Import of NR	0	0.00	0.00
4	NEW-SR	0	0.00	0.00
4	NER Import	0	0.00	0.00

### Voltage Profile for the day of 20-Feb-2020

Region	Station	%age of time Voltage below 728/380 kV	%age of time Voltage between 728/380 kV & 800/420 kV	%age of time Voltage above 800/420 kV	Voltage deviation index (%age of time voltage is outside IEGC band)	
NR	Agra	0.00%	100.00%	0.00%	0.00%	
	Agra (Fatehabad)	0.00%	81.74%	18.26%	18.26%	
	Anpara-C	0.00%	100.00%	0.00%	0.00%	
	Anpara-D	0.00%	100.00%	0.00%	0.00%	
	Anta	0.00%	100.00%	0.00%	0.00%	
	Ballia	0.00%	100.00%	0.00%	0.00%	
	Bara	0.00%	100.00%	0.00%	0.00%	
	Bhiwani	0.00%	99.58%	0.42%	0.42%	
	Fatehpur	0.00%	100.00%	0.00%	0.00%	
	Jhatikara	0.00%	100.00%	0.00%	0.00%	
	Kanpur GIS	0.00%	100.00%	0.00%	0.00%	
	Lucknow	0.00%	79.44%	20.56%	20.56%	
	Lalitpur	0.00%	100.00%	0.00%	0.00%	
	Meerut	0.00%	99.51%	0.49%	0.49%	
	Phagi	0.00%	100.00%	0.00%	0.00%	
Varanasi	0.00%	100.00%	0.00%	0.00%		
Unnao	0.00%	100.00%	0.00%	0.00%		
WR	Akola	0.00%	100.00%	0.00%	0.00%	
	Aurangabad	0.00%	100.00%	0.00%	0.00%	
	Bhopal (BDTCL)	0.00%	100.00%	0.00%	0.00%	
	Bilaspur	0.00%	100.00%	0.00%	0.00%	
	Bina	0.00%	100.00%	0.00%	0.00%	
	Champa	0.00%	100.00%	0.00%	0.00%	
	Gwalior	0.00%	100.00%	0.00%	0.00%	
	Indore	0.00%	100.00%	0.00%	0.00%	
	Koradi	0.00%	100.00%	0.00%	0.00%	
	Pune	0.00%	100.00%	0.00%	0.00%	
	Raigarh Pooling	0.00%	100.00%	0.00%	0.00%	
	Sasan	0.00%	100.00%	0.00%	0.00%	
	Satna	0.00%	100.00%	0.00%	0.00%	
	Seoni	0.00%	100.00%	0.00%	0.00%	
	Sipat	0.00%	100.00%	0.00%	0.00%	
	Solapur	0.00%	100.00%	0.00%	0.00%	
	Tamnar	0.00%	100.00%	0.00%	0.00%	
	Tirora	0.00%	100.00%	0.00%	0.00%	
	Kurmool	0.00%	100.00%	0.00%	0.00%	
	Nellore PS	0.00%	100.00%	0.00%	0.00%	
	Raichur	0.00%	100.00%	0.00%	0.00%	
	SR	Nizamabad	0.00%	95.35%	4.65%	4.65%
		Srikakulam	0.00%	100.00%	0.00%	0.00%
Thiruvallam		0.00%	100.00%	0.00%	0.00%	
Vemagiri		0.00%	80.42%	19.58%	19.58%	
ER	Angul	0.00%	100.00%	0.00%	0.00%	
	Gaya	0.00%	100.00%	0.00%	0.00%	
	Jharsuguda	0.00%	100.00%	0.00%	0.00%	
	Ranchi	0.00%	100.00%	0.00%	0.00%	
	Balipara (400 kV)	0.00%	100.00%	0.00%	0.00%	
NER	Bongaigaon (400 kV)	0.00%	100.00%	0.00%	0.00%	
	Palatana (400 kV)	0.00%	89.72%	10.28%	10.28%	
	Misa (400 kV)	0.00%	95.07%	4.93%	4.93%	
	Biswanath Chariali (400 kV)	0.00%	100.00%	0.00%	0.00%	
	Silchar (400 kV)	0.00%	83.82%	16.18%	16.18%	

Remarks: Unless otherwise specified, station may be treated as 765kV S/S.