

**POWER SYSTEM OPERATION CORPORATION LIMITED**  
**NATIONAL LOAD DESPATCH CENTRE**  
**NEW DELHI**

Date of Reporting: 29-May-20  
System Reliability Indices Report for: 28-May-20

**Percentage (%) of times ATC was violated**

S.No.	Corridor	Number of Blocks Violated	Number of Hours Violated	%Violation
1	WR-NR	0	0.00	0.00
2	ER-NR	0	0.00	0.00
3	Import of NR	0	0.00	0.00
4	NEW-SR	0	0.00	0.00
5	NER Import	0	0.00	0.00

**Percentage(%) of times (N-1) Criteria was violated**

S.No.	Corridor	Number of Blocks Violated	Number of Hours Violated	%Violation
1	WR-NR	0	0.00	0.00
2	ER-NR	0	0.00	0.00
3	Import of NR	0	0.00	0.00
4	NEW-SR	0	0.00	0.00
4	NER Import	0	0.00	0.00

Remarks: Flows crossing Total Transfer Capability (TTC) on interregional corridors has been worked out as a proxy for (N-1) violation.

### Voltage Profile for the day of 28-May-2020

Region	Station	%age of time Voltage below 728/380 kV	%age of time Voltage between 728/380 kV & 800/420 kV	%age of time Voltage above 800/420 kV	Voltage deviation index (%age of time voltage is outside IEGC band)
NR	Agra	0.00%	98.68%	1.32%	1.32%
	Anpara-D	0.00%	100.00%	0.00%	0.00%
	Anta	0.00%	100.00%	0.00%	0.00%
	Ballia	0.00%	100.00%	0.00%	0.00%
	Bara	0.00%	100.00%	0.00%	0.00%
	Bhiwani	0.00%	96.94%	3.06%	3.06%
	Bareilly	0.00%	97.64%	2.36%	2.36%
	Jhatikara	0.00%	98.89%	1.11%	1.11%
	Kanpur GIS	0.00%	100.00%	0.00%	0.00%
	Lucknow	0.00%	93.19%	6.81%	6.81%
	Lalitpur	0.00%	99.86%	0.00%	0.00%
	Meerut	0.00%	99.38%	0.63%	0.63%
	Moga	0.00%	99.65%	0.35%	0.35%
	Phagi	0.00%	97.29%	2.71%	2.71%
Varanasi	0.00%	100.00%	0.00%	0.00%	
Unnao	0.00%	100.00%	0.00%	0.00%	
WR	Akola	0.00%	100.00%	0.00%	0.00%
	Aurangabad	0.00%	100.00%	0.00%	0.00%
	Bhopal (BDTCL)	0.00%	100.00%	0.00%	0.00%
	Bilaspur	0.00%	100.00%	0.00%	0.00%
	Bina	0.00%	97.92%	2.08%	2.08%
	Champa	0.00%	98.54%	1.46%	1.46%
	Dharamjaigarh	0.00%	100.00%	0.00%	0.00%
	Dhule (BDTCL)	0.00%	100.00%	0.00%	0.00%
	Ektuni	0.00%	100.00%	0.00%	0.00%
	Gwalior	0.00%	98.33%	1.67%	1.67%
	Indore	0.00%	100.00%	0.00%	0.00%
	Jabalpur	0.00%	95.69%	4.31%	4.31%
	Koradi	0.00%	100.00%	0.00%	0.00%
	Pune	0.00%	100.00%	0.00%	0.00%
	Raigarh Pooling	0.00%	100.00%	0.00%	0.00%
	Raipur Pooling	0.00%	100.00%	0.00%	0.00%
	Sasan	0.00%	100.00%	0.00%	0.00%
	Satna	0.00%	100.00%	0.00%	0.00%
	Seoni	0.00%	100.00%	0.00%	0.00%
	Sipat	0.00%	100.00%	0.00%	0.00%
Solapur	0.00%	94.31%	5.69%	5.69%	
Tamnar	0.00%	100.00%	0.00%	0.00%	
Tirora	0.00%	100.00%	0.00%	0.00%	
Vadodara	0.00%	100.00%	0.00%	0.00%	
Vindhyachal PS	0.00%	100.00%	0.00%	0.00%	
Wardha	0.00%	96.25%	3.75%	3.75%	
SR	Kurnool	0.00%	97.78%	2.22%	2.22%
	Nellore PS	0.00%	97.36%	2.64%	2.64%
	Raichur	0.00%	97.99%	2.01%	2.01%
	Nizamabad	0.00%	80.07%	19.93%	19.93%
	Srikakulam	0.00%	100.00%	0.00%	0.00%
	Thiruvallam	0.00%	100.00%	0.00%	0.00%
Vemagiri	0.00%	94.90%	5.10%	5.10%	
ER	Angul	0.00%	100.00%	0.00%	0.00%
	Gaya	0.00%	100.00%	0.00%	0.00%
	Jharsuguda	0.00%	87.78%	12.22%	12.22%
	Ranchi	0.00%	100.00%	0.00%	0.00%
	Sasaram	0.00%	100.00%	0.00%	0.00%
NER	Azara (400 kV)	0.00%	100.00%	0.00%	0.00%
	Balipara (400 kV)	0.00%	100.00%	0.00%	0.00%
	Bongaigaon (400 kV)	0.00%	100.00%	0.00%	0.00%
	Bongaigaon TPS (400 kV)	0.00%	100.00%	0.00%	0.00%
	Byrnihat (400 kV)	0.00%	100.00%	0.00%	0.00%
	Palatana (400 kV)	0.00%	100.00%	0.00%	0.00%
	Misa (400 kV)	0.00%	100.00%	0.00%	0.00%
	Ranganadi (400 kV)	0.00%	100.00%	0.00%	0.00%
	Biswanath Chariali (400 kV)	0.00%	100.00%	0.00%	0.00%
Silchar (400 kV)	0.00%	100.00%	0.00%	0.00%	

Remarks: Unless otherwise specified, station may be treated as 765kV S/S.