




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

02-Aug-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	2.36	19.76	30.02	27.95	16.28	3.23	0.40	52.16	37.37	10.46	6.89	97.24	12.23

Average Frequency	49.90	Frequency Variation Index :	0.237	Standard Deviation :	0.113
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.219	13:05:00	Max	50.172	13:15:00
Min	49.64	8:43:00	Min	49.700	5:30:00

