




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NEHU:Frequency

National Grid Frequency Profile for

10-Aug-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.88	5.97	12.11	36.20	38.46	5.76	0.61	18.97	62.07	18.96	13.13	98.51	31.09

Average Frequency		49.97	Frequency Variation Index :		0.102	Standard Deviation :		0.097
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.244	18:02:30	Max	50.127	18:15:00
Min	49.61	19:17:10	Min	49.768	22:30:00

