




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for 15/06/2014



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.51	5.15	17.37	33.65	31.86	8.66	2.80	23.04	50.69	26.26	14.86	96.69	22.36

Average Frequency		49.98	Frequency Variation Index :		0.130	Standard Deviation :		0.112
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.417	18:03:50	Max	50.268	18:15:00
Min	49.67	10:56:40	Min	49.714	11:00:00