




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

MEERUT:Frequency

National Grid Frequency Profile for 23/06/2014



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	2.13	7.32	15.45	35.10	29.33	8.73	1.93	24.92	52.51	22.57	12.50	95.94	23.10

Average Frequency	49.96	Frequency Variation Index :	0.159	Standard Deviation :	0.121
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.352	8:03:40	Max	50.237	8:00:00
Min	49.52	22:08:10	Min	49.611	22:30:00