




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

SRIPERUMBUDUR:Frequency

National Grid Frequency Profile for 27/06/2014



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	20.75	31.80	33.07	10.78	3.08	0.49	0.04	85.66	12.50	1.84	1.40	79.21	2.95

Average Frequency		49.79	Frequency Variation Index :		0.590	Standard Deviation :		0.117
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.16	18:01:50	Max	50.031	18:15:00
Min	49.32	9:13:50	Min	49.531	9:30:00