




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

MEERUT:Frequency

National Grid Frequency Profile for

05/06/14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	5.07	10.42	24.67	34.84	21.60	3.38	0.02	40.19	49.92	9.90	6.82	94.91	22.87

Average Frequency		49.92	Frequency Variation Index :		0.201	Standard Deviation :		0.115
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.195	18:02:50	Max	50.124	18:15:00
Min	49.52	12:18:00	Min	49.630	15:30:00