




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

MOHINDERGARH:Frequency

National Grid Frequency Profile for

08/06/14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.66	1.79	12.56	37.12	37.92	9.13	0.82	15.02	60.01	24.97	15.08	98.52	28.31

Average Frequency		49.99	Frequency Variation Index :		0.086	Standard Deviation :		0.092
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.297	18:03:30	Max	50.215	18:15:00
Min	49.58	20:09:10	Min	49.724	20:15:00