

Voltage Profile for the day of 15-Feb-2019

| Region | Station | %age of time Voltage below 728/380 kV | %age of time Voltage between 728/380 kV & 800/420 kV | %age of time Voltage above 800/420 kV | Voltage deviation index (%age of time voltage is outside IEGC band) | Maximum Voltage (kV) | Minimum Voltage (kV) | Average Voltage (kV) |
|------------------|-----------------------------|---------------------------------------|--|---------------------------------------|---|----------------------|----------------------|----------------------|
| NR | Agra | 0.00% | 100.00% | 0.00% | 0.00% | 798 | 766 | 783 |
| | Agra (Fatehabad) | 0.00% | 99.93% | 0.07% | 0.07% | 820 | 757 | 780 |
| | Anpara-C | 0.00% | 100.00% | 0.00% | 0.00% | 786 | 759 | 769 |
| | Anpara-D | 0.00% | 100.00% | 0.00% | 0.00% | 784 | 757 | 767 |
| | Anta | 0.00% | 100.00% | 0.00% | 0.00% | 788 | 769 | 781 |
| | Ballia | 0.00% | 100.00% | 0.00% | 0.00% | 790 | 759 | 775 |
| | Bhiwani | 0.00% | 100.00% | 0.00% | 0.00% | 800 | 774 | 788 |
| | Bareilly | 0.00% | 100.00% | 0.00% | 0.00% | 757 | 752 | 758 |
| | Fatehpur | 0.00% | 100.00% | 0.00% | 0.00% | 780 | 749 | 765 |
| | Greater Noida | 0.00% | 86.18% | 13.82% | 13.82% | 804 | 774 | 792 |
| | Jhatikara | 0.00% | 99.51% | 0.49% | 0.49% | 801 | 770 | 787 |
| | Kanpur GIS | 0.00% | 100.00% | 0.00% | 0.00% | 760 | 754 | 758 |
| | Lucknow | 0.00% | 89.65% | 10.35% | 10.35% | 804 | 768 | 787 |
| | Lalitpur | 0.00% | 17.43% | 0.00% | 0.00% | 795 | 764 | 136 |
| | Meerut | 0.00% | 94.72% | 2.64% | 2.64% | 802 | 766 | 787 |
| | Moga | 0.00% | 100.00% | 0.00% | 0.00% | 787 | 755 | 770 |
| | Phagi | 0.00% | 100.00% | 0.00% | 0.00% | 797 | 765 | 783 |
| Varanasi | 0.00% | 100.00% | 0.00% | 0.00% | 792 | 764 | 778 | |
| Unnao | 0.00% | 100.00% | 0.00% | 0.00% | 795 | 752 | 755 | |
| WR | Akola | 0.00% | 100.00% | 0.00% | 0.00% | 799 | 760 | 782 |
| | Aurangabad | 0.00% | 100.00% | 0.00% | 0.00% | 799 | 767 | 787 |
| | Bhopal (BDTCL) | 0.00% | 100.00% | 0.00% | 0.00% | 794 | 762 | 779 |
| | Bilaspur | 0.00% | 100.00% | 0.00% | 0.00% | 779 | 761 | 772 |
| | Bina | 0.00% | 100.00% | 0.00% | 0.00% | 799 | 770 | 786 |
| | Champa | 0.00% | 72.22% | 15.07% | 15.07% | 806 | 784 | 796 |
| | Dharamjaigarh | 0.00% | 100.00% | 0.00% | 0.00% | 789 | 771 | 781 |
| | Dhule (BDTCL) | 0.00% | 100.00% | 0.00% | 0.00% | 796 | 766 | 781 |
| | Gwalior | 0.00% | 100.00% | 0.00% | 0.00% | 800 | 770 | 786 |
| | Indore | 0.00% | 100.00% | 0.00% | 0.00% | 788 | 753 | 775 |
| | Jabalpur | 0.00% | 99.86% | 0.14% | 0.14% | 800 | 773 | 788 |
| | Koradi | 0.00% | 100.00% | 0.00% | 0.00% | 784 | 755 | 771 |
| | Pune | 0.00% | 100.00% | 0.00% | 0.00% | 797 | 744 | 774 |
| | Raigarh Pooling | 0.00% | 82.36% | 17.64% | 17.64% | 805 | 786 | 796 |
| | Sasan | 0.00% | 100.00% | 0.00% | 0.00% | 784 | 767 | 776 |
| | Satna | 0.00% | 100.00% | 0.00% | 0.00% | 794 | 771 | 783 |
| | Seoni | 0.00% | 100.00% | 0.00% | 0.00% | 795 | 766 | 782 |
| | Sipat | 0.00% | 100.00% | 0.00% | 0.00% | 777 | 762 | 771 |
| | Solapur | 0.00% | 96.60% | 3.40% | 3.40% | 805 | 767 | 791 |
| | Tamnar | 0.00% | 76.39% | 23.61% | 23.61% | 805 | 787 | 797 |
| Tirora | 0.00% | 100.00% | 0.00% | 0.00% | 773 | 751 | 765 | |
| Vadodara | 0.00% | 100.00% | 0.00% | 0.00% | 797 | 766 | 783 | |
| Vindhyachal PS | 0.00% | 100.00% | 0.00% | 0.00% | 785 | 768 | 777 | |
| Wardha | 0.00% | 93.89% | 6.11% | 6.11% | 803 | 773 | 790 | |
| SR | Kurnool | 0.00% | 97.78% | 2.22% | 2.22% | 801 | 762 | 783 |
| | Nellore PS | 0.00% | 100.00% | 0.00% | 0.00% | 795 | 760 | 778 |
| | Raichur | 0.00% | 100.00% | 0.00% | 0.00% | 799 | 765 | 783 |
| | Nizamabad | 0.00% | 73.19% | 26.81% | 26.81% | 809 | 779 | 795 |
| | Srikakulam | 0.00% | 100.00% | 0.00% | 0.00% | 791 | 773 | 784 |
| | Thiruvallam | 0.00% | 100.00% | 0.00% | 0.00% | 795 | 757 | 777 |
| Vemagiri | 0.00% | 100.00% | 0.00% | 0.00% | 780 | 754 | 767 | |
| ER | Angul | 0.00% | 100.00% | 0.00% | 0.00% | 790 | 771 | 781 |
| | Gaya | 0.00% | 100.00% | 0.00% | 0.00% | 783 | 753 | 769 |
| | Jharsuguda | 0.00% | 99.58% | 0.42% | 0.42% | 801 | 781 | 793 |
| | Ranchi | 0.00% | 100.00% | 0.00% | 0.00% | 788 | 770 | 782 |
| Sasaram | 0.00% | 100.00% | 0.00% | 0.00% | 775 | 746 | 760 | |
| NER | Azara (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% | 412 | 404 | 408 |
| | Balipara (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% | 415 | 396 | 408 |
| | Bongaigaon (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% | 413 | 396 | 406 |
| | Byrnihat (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% | 412 | 404 | 408 |
| | Palatana (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% | 416 | 409 | 405 |
| | Misa (400 kV) | 0.00% | 93.06% | 6.94% | 6.94% | 421 | 401 | 413 |
| | Biswanath Chariali (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% | 414 | 394 | 407 |
| Silchar (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% | 415 | 399 | 407 | |

Remarks: Unless otherwise specified, station may be treated as 765kV S/S.