

POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE
NEW DELHI

Date of Reporting: **8-Apr-20**
System Reliability Indices Report for: **7-Apr-20**

Percentage (%) of times ATC was violated

| S.No. | Corridor | Number of Blocks Violated | Number of Hours Violated | %Violation |
|-------|------------|---------------------------|--------------------------|------------|
| 1 | WR-NR | 0 | 0.00 | 0.00 |
| 2 | ER-NR | 0 | 0.00 | 0.00 |
| 4 | NEW-SR | 0 | 0.00 | 0.00 |
| 5 | NER Import | 0 | 0.00 | 0.00 |

Percentage(%) of times (N-1) Criteria was violated

| S.No. | Corridor | Number of Blocks Violated | Number of Hours Violated | %Violation |
|-------|--------------|---------------------------|--------------------------|------------|
| 1 | WR-NR | 0 | 0.00 | 0.00 |
| 2 | ER-NR | 0 | 0.00 | 0.00 |
| 3 | Import of NR | 0 | 0.00 | 0.00 |
| 4 | NEW-SR | 0 | 0.00 | 0.00 |
| 4 | NER Import | 0 | 0.00 | 0.00 |

Remarks: Flows crossing Total Transfer Capability (TTC) on interregional corridors has been worked out as a proxy for (N-1) violation.

Voltage Profile for the day of 07-Apr-2020

| Region | Station | %age of time Voltage below 728/380 kV | %age of time Voltage between 728/380 kV & 800/420 kV | %age of time Voltage above 800/420 kV | Voltage deviation index (%age of time voltage is outside IEGC band) |
|------------------|-----------------------------|---------------------------------------|--|---------------------------------------|---|
| NR | Agra | 0.00% | 100.00% | 0.00% | 0.00% |
| | Anpara-C | 0.00% | 100.00% | 0.00% | 0.00% |
| | Anpara-D | 0.00% | 100.00% | 0.00% | 0.00% |
| | Anta | 0.00% | 100.00% | 0.00% | 0.00% |
| | Ballia | 0.00% | 100.00% | 0.00% | 0.00% |
| | Bara | 0.00% | 100.00% | 0.00% | 0.00% |
| | Bhiwani | 0.00% | 100.00% | 0.00% | 0.00% |
| | Bareilly | 0.00% | 90.83% | 9.17% | 9.17% |
| | Fatehpur | 0.00% | 100.00% | 0.00% | 0.00% |
| | Greater Noida | 0.00% | 91.67% | 8.33% | 8.33% |
| | Kanpur GIS | 0.00% | 100.00% | 0.00% | 0.00% |
| | Lucknow | 0.00% | 99.51% | 0.49% | 0.49% |
| | Lalitpur | 2.22% | 97.78% | 0.00% | 2.22% |
| | Moga | 0.00% | 100.00% | 0.00% | 0.00% |
| | Phagi | 0.00% | 100.00% | 0.00% | 0.00% |
| Varanasi | 0.00% | 100.00% | 0.00% | 0.00% | |
| Unnao | 0.00% | 100.00% | 0.00% | 0.00% | |
| WR | Akola | 0.00% | 100.00% | 0.00% | 0.00% |
| | Aurangabad | 0.00% | 100.00% | 0.00% | 0.00% |
| | Bhopal (BDTCL) | 0.00% | 100.00% | 0.00% | 0.00% |
| | Bilaspur | 0.00% | 100.00% | 0.00% | 0.00% |
| | Bina | 0.00% | 100.00% | 0.00% | 0.00% |
| | Champa | 0.00% | 100.00% | 0.00% | 0.00% |
| | Dharamjaigarh | 0.00% | 100.00% | 0.00% | 0.00% |
| | Dhule (BDTCL) | 0.00% | 100.00% | 0.00% | 0.00% |
| | Ektuni | 0.00% | 100.00% | 0.00% | 0.00% |
| | Gwalior | 0.00% | 100.00% | 0.00% | 0.00% |
| | Indore | 0.00% | 100.00% | 0.00% | 0.00% |
| | Jabalpur | 0.00% | 100.00% | 0.00% | 0.00% |
| | Koradi | 0.00% | 100.00% | 0.00% | 0.00% |
| | Pune | 0.00% | 100.00% | 0.00% | 0.00% |
| | Raigarh Pooling | 0.00% | 100.00% | 0.00% | 0.00% |
| | Raipur Pooling | 0.00% | 100.00% | 0.00% | 0.00% |
| | Sasan | 0.00% | 100.00% | 0.00% | 0.00% |
| | Satna | 0.00% | 100.00% | 0.00% | 0.00% |
| | Seoni | 0.00% | 100.00% | 0.00% | 0.00% |
| | Sipat | 0.00% | 100.00% | 0.00% | 0.00% |
| Solapur | 0.00% | 100.00% | 0.00% | 0.00% | |
| Tamnar | 0.00% | 100.00% | 0.00% | 0.00% | |
| Tirora | 0.00% | 100.00% | 0.00% | 0.00% | |
| Vadodara | 0.00% | 100.00% | 0.00% | 0.00% | |
| Vindhyachal PS | 0.00% | 100.00% | 0.00% | 0.00% | |
| Wardha | 0.00% | 100.00% | 0.00% | 0.00% | |
| SR | Kurnool | 0.00% | 100.00% | 0.00% | 0.00% |
| | Nellore PS | 0.00% | 100.00% | 0.00% | 0.00% |
| | Raichur | 0.00% | 100.00% | 0.00% | 0.00% |
| | Nizamabad | 0.00% | 99.17% | 0.83% | 0.83% |
| | Srikakulam | 0.00% | 100.00% | 0.00% | 0.00% |
| | Thiruvallam | 0.00% | 100.00% | 0.00% | 0.00% |
| Vemagiri | 0.00% | 98.26% | 1.74% | 1.74% | |
| ER | Angul | 0.00% | 100.00% | 0.00% | 0.00% |
| | Gaya | 0.00% | 100.00% | 0.00% | 0.00% |
| Ranchi | 0.00% | 100.00% | 0.00% | 0.00% | |
| NER | Azara (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% |
| | Balipara (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% |
| | Bongaigaon (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% |
| | Bongaigaon TPS (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% |
| | Byrnhat (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% |
| | Palatana (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% |
| | Misa (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% |
| | Ranganadi (400 kV) | 0.00% | 97.78% | 2.22% | 2.22% |
| | Biswanath Chariali (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% |
| Silchar (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% | |

Remarks: Unless otherwise specified, station may be treated as 765kV S/S.