

POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE
NEW DELHI

Date of Reporting: 29-08-2021

System Reliability Indices Report for: 28-08-2021

Percentage (%) of times ATC was violated

| S.No. | Corridor | Number of Blocks Violated | Number of Hours Violated | %Violation |
|-------|--------------|---------------------------|--------------------------|------------|
| 1 | WR-NR | 0 | 0.00 | 0.00 |
| 2 | ER-NR | 0 | 0.00 | 0.00 |
| 3 | Import of NR | 0 | 0.00 | 0.00 |
| 4 | NEW-SR | 0 | 0.00 | 0.00 |
| 5 | NER Import | 0 | 0.00 | 0.00 |

Percentage(%) of times (N-1) Criteria was violated

| | | | | |
|---|--------------|---|------|------|
| 1 | WR-NR | 0 | 0.00 | 0.00 |
| 2 | ER-NR | 0 | 0.00 | 0.00 |
| 3 | Import of NR | 0 | 0.00 | 0.00 |
| 4 | NEW-SR | 0 | 0.00 | 0.00 |
| 4 | NER Import | 0 | 0.00 | 0.00 |

Voltage Profile for the day of 28-08-2021

| Region | Station | %age of time Voltage below 728/380 kV | %age of time Voltage between 728/380 kV & 800/420 kV | %age of time Voltage above 800/420 kV | Voltage deviation index (%age of time voltage is outside IEGC band) | Maximum Voltage (kV) | Minimum Voltage (kV) | Average Voltage (kV) |
|------------------|-----------------------------|---------------------------------------|--|---------------------------------------|---|----------------------|----------------------|----------------------|
| NR | Agra | 0.00% | 100.00% | 0.00% | 0.00% | 789 | 760 | 772 |
| | Agra (Fatehabad) | 0.00% | 100.00% | 0.00% | 0.00% | 789 | 760 | 772 |
| | Anpara-C | 0.00% | 100.00% | 0.00% | 0.00% | 772 | 765 | 767 |
| | Anpara-D | 0.00% | 100.00% | 0.00% | 0.00% | 772 | 765 | 767 |
| | Anta | 0.00% | 100.00% | 0.00% | 0.00% | 799 | 766 | 780 |
| | Ballia | 0.00% | 100.00% | 0.00% | 0.00% | 781 | 759 | 769 |
| | Bara | 0.00% | 100.00% | 0.00% | 0.00% | 783 | 763 | 769 |
| | Bhiwani | 0.00% | 100.00% | 0.00% | 0.00% | 784 | 759 | 771 |
| | Bareilly | 0.00% | 100.00% | 0.00% | 0.00% | 792 | 760 | 773 |
| | Fatehpur | 0.00% | 100.00% | 0.00% | 0.00% | 780 | 754 | 765 |
| | Greater Noida | 0.00% | 100.00% | 0.00% | 0.00% | 795 | 764 | 776 |
| | Jhatikara | 0.00% | 100.00% | 0.00% | 0.00% | 783 | 755 | 768 |
| | Kanpur GIS | 0.00% | 100.00% | 0.00% | 0.00% | 782 | 756 | 767 |
| | Lucknow | 0.00% | 100.00% | 0.00% | 0.00% | 786 | 757 | 769 |
| | Lalitpur | 0.00% | 100.00% | 0.00% | 0.00% | 776 | 760 | 766 |
| | Meerut | 0.00% | 100.00% | 0.00% | 0.00% | 794 | 763 | 776 |
| | Moqa | 0.00% | 100.00% | 0.00% | 0.00% | 788 | 757 | 771 |
| Phagi | 0.00% | 100.00% | 0.00% | 0.00% | 798 | 758 | 775 | |
| Varanasi | 0.00% | 100.00% | 0.00% | 0.00% | 784 | 765 | 773 | |
| WR | Akola | 0.00% | 100.00% | 0.00% | 0.00% | 781 | 766 | 773 |
| | Aurangabad | 0.00% | 100.00% | 0.00% | 0.00% | 785 | 761 | 774 |
| | Bhopal (BDTCL) | 0.00% | 100.00% | 0.00% | 0.00% | 777 | 755 | 766 |
| | Bilaspur | 0.00% | 100.00% | 0.00% | 0.00% | 780 | 771 | 776 |
| | Bina | 0.00% | 100.00% | 0.00% | 0.00% | 786 | 767 | 774 |
| | Champa | 0.00% | 100.00% | 0.00% | 0.00% | 792 | 782 | 788 |
| | Dharamjaigarh | 0.00% | 100.00% | 0.00% | 0.00% | 784 | 772 | 778 |
| | Dhule (BDTCL) | 0.00% | 100.00% | 0.00% | 0.00% | 790 | 761 | 773 |
| | Ektuni | 0.00% | 100.00% | 0.00% | 0.00% | 790 | 761 | 771 |
| | Gwalior | 0.00% | 100.00% | 0.00% | 0.00% | 790 | 764 | 774 |
| | Indore | 0.00% | 100.00% | 0.00% | 0.00% | 782 | 752 | 767 |
| | Jabalpur | 0.00% | 100.00% | 0.00% | 0.00% | 792 | 777 | 785 |
| | Koradi | 0.00% | 100.00% | 0.00% | 0.00% | 773 | 763 | 768 |
| | Pune | 0.00% | 100.00% | 0.00% | 0.00% | 793 | 758 | 778 |
| | Raigarh Pooling | 0.00% | 100.00% | 0.00% | 0.00% | 791 | 783 | 788 |
| | Raipur Pooling | 0.00% | 100.00% | 0.00% | 0.00% | 790 | 782 | 786 |
| | Sasan | 0.00% | 100.00% | 0.00% | 0.00% | 783 | 772 | 776 |
| | Satna | 0.00% | 100.00% | 0.00% | 0.00% | 788 | 775 | 779 |
| | Seoni | 0.00% | 100.00% | 0.00% | 0.00% | 785 | 769 | 777 |
| | Sipat | 0.00% | 100.00% | 0.00% | 0.00% | 779 | 773 | 777 |
| | Solapur | 0.00% | 100.00% | 0.00% | 0.00% | 791 | 771 | 782 |
| | Tamnar | 0.00% | 100.00% | 0.00% | 0.00% | 793 | 786 | 790 |
| | Tirora | 0.00% | 100.00% | 0.00% | 0.00% | 769 | 762 | 765 |
| | Vadodara | 0.00% | 100.00% | 0.00% | 0.00% | 779 | 755 | 766 |
| Vindhyachal PS | 0.00% | 100.00% | 0.00% | 0.00% | 779 | 755 | 779 | |
| Wardha | 0.00% | 100.00% | 0.00% | 0.00% | 779 | 755 | 785 | |
| SR | Kurnool | 0.00% | 100.00% | 0.00% | 0.00% | 780 | 759 | 770 |
| | Nellore PS | 0.00% | 100.00% | 0.00% | 0.00% | 780 | 762 | 772 |
| | Raichur | 0.00% | 100.00% | 0.00% | 0.00% | 786 | 764 | 776 |
| | Nizamabad | 0.00% | 100.00% | 0.00% | 0.00% | 798 | 780 | 787 |
| | Srikakulam | 0.00% | 77.92% | 22.08% | 22.08% | 804 | 783 | 791 |
| | Thiruvallam | 0.00% | 77.92% | 22.08% | 22.08% | 804 | 783 | 791 |
| | Vemagiri | 0.00% | 99.93% | 0.07% | 0.07% | 800 | 776 | 788 |
| ER | Angul | 0.00% | 100.00% | 0.00% | 0.00% | 796 | 771 | 783 |
| | Gaya | 0.00% | 100.00% | 0.00% | 0.00% | 777 | 759 | 767 |
| | Jharsuguda | 0.00% | 99.86% | 0.14% | 0.14% | 800 | 783 | 792 |
| | Ranchi | 0.00% | 100.00% | 0.00% | 0.00% | 786 | 769 | 778 |
| | Sasaram | 0.00% | 100.00% | 0.00% | 0.00% | 770 | 752 | 759 |
| NER | Balipara (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% | 408 | 396 | 404 |
| | Bongaigaon (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% | 411 | 401 | 408 |
| | Bongaigaon TPS (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% | 417 | 404 | 412 |
| | Palatana (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% | 410 | 402 | 407 |
| | Misa (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% | 410 | 399 | 406 |
| | Ranganadi (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% | 414 | 405 | 411 |
| | Biswanath Chariali (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% | 411 | 399 | 406 |
| Silchar (400 kV) | 0.00% | 100.00% | 0.00% | 0.00% | 412 | 405 | 409 | |

Remarks: Unless otherwise specified, station may be treated as 765kV S/S.