




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

15-Apr-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.37	5.36	23.42	42.80	23.14	4.88	0.03	29.17	58.58	12.26	7.40	99.60	22.23

Average Frequency	49.95	Frequency Variation Index :	0.109	Standard Deviation :	0.090
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.201	13:03:30	Max	50.099	18:00:00
Min	49.60	22:38:50	Min	49.755	22:45:00