




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

16-Apr-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	1.97	13.81	27.90	30.83	21.19	4.27	0.02	43.70	43.95	12.35	8.09	98.01	17.99

Average Frequency	49.92	Frequency Variation Index :	0.186	Standard Deviation :	0.110
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.197	8:03:40	Max	50.105	7:15:00
Min	49.58	9:13:50	Min	49.730	11:30:00