




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

18-Apr-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.13	3.55	16.65	39.54	27.72	10.91	1.50	20.34	56.45	23.22	10.87	98.37	23.17

Average Frequency	49.98	Frequency Variation Index :	0.103	Standard Deviation :	0.099
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.331	6:02:00	Max	50.208	5:30:00
Min	49.67	19:15:10	Min	49.801	19:30:00