




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

19-Apr-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	1.09	9.77	31.54	44.43	11.99	1.18	10.87	56.10	33.03	19.97	98.82	28.24

Average Frequency		50.01	Frequency Variation Index :		0.075	Standard Deviation :		0.086
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.25	18:34:30	Max	50.184	17:45:00
Min	49.71	14:30:00	Min	49.823	14:45:00