




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

22-Apr-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.07	3.74	22.28	39.97	28.50	5.23	0.22	26.10	57.33	16.57	11.19	99.71	22.09

Average Frequency	49.96	Frequency Variation Index :	0.096	Standard Deviation :	0.089
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.235	17:02:50	Max	50.079	17:15:00
Min	49.69	1:10:50	Min	49.776	1:15:00