




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

HISSAR:Frequency

National Grid Frequency Profile for

24-Apr-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	2.16	11.96	36.15	35.83	12.05	1.76	0.09	50.30	43.83	5.87	4.06	97.75	13.36

Average Frequency	49.90	Frequency Variation Index :	0.192	Standard Deviation :	0.095
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.21	18:01:50	Max	50.059	0:00:00
Min	49.59	4:13:00	Min	49.700	4:15:00