




**POWER SYSTEM OPERATION CORPORATION LIMITED**  
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

HISSAR:Frequency

National Grid Frequency Profile for

25-Apr-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	1.28	13.53	31.45	33.85	17.82	2.03	0.03	46.30	46.32	7.38	5.36	98.69	18.19

<b>Average Frequency</b>		<b>49.91</b>	<b>Frequency Variation Index :</b>		<b>0.180</b>	<b>Standard Deviation :</b>		<b>0.099</b>
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.19	18:01:00	Max	50.059	7:15:00
Min	49.62	19:37:50	Min	49.708	23:15:00