




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

MOHINDERGARH:Frequency

National Grid Frequency Profile for

27-Apr-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	4.33	11.98	22.93	33.82	18.88	6.76	1.30	39.26	44.63	16.11	8.11	94.37	15.02

Average Frequency		49.93	Frequency Variation Index :		0.215	Standard Deviation :		0.127
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.422	18:03:00	Max	50.287	18:15:00
Min	49.59	1:32:20	Min	49.628	1:45:00