




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

MEERUT:Frequency

National Grid Frequency Profile for

28-Apr-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	1.92	8.85	24.22	35.91	21.35	6.50	1.23	35.01	50.41	14.58	6.97	96.84	21.72

Average Frequency		49.94	Frequency Variation Index :		0.166	Standard Deviation :		0.114
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.307	18:02:50	Max	50.148	7:15:00
Min	49.58	22:22:50	Min	49.726	23:00:00