




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

HISSAR:Frequency

National Grid Frequency Profile for

30-Apr-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	1.84	8.11	22.28	39.98	22.73	5.01	0.05	32.25	53.96	13.80	8.81	98.11	19.42

Average Frequency		49.94	Frequency Variation Index :		0.149	Standard Deviation :		0.105
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.204	8:09:20	Max	50.153	8:15:00
Min	49.56	21:04:40	Min	49.689	14:45:00