




**POWER SYSTEM OPERATION CORPORATION LIMITED**  
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

VIJAYAWADA:Frequency

National Grid Frequency Profile for

11-Aug-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	1.97	14.73	21.35	34.86	24.07	3.02	0.00	38.05	49.89	12.06	9.04	98.03	20.56

<b>Average Frequency</b>		<b>49.92</b>	<b>Frequency Variation Index :</b>		<b>0.178</b>	<b>Standard Deviation :</b>		<b>0.108</b>
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.191	6:02:10	Max	50.071	0:00:00
Min	49.57	19:25:10	Min	49.677	19:30:00

