




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

15-Aug-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	1.53	8.42	20.09	30.93	30.02	6.84	2.17	30.06	48.77	21.17	12.23	96.30	21.89

Average Frequency	49.96	Frequency Variation Index :	0.154	Standard Deviation :	0.118
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.341	17:07:30	Max	50.268	17:15:00
Min	49.60	0:54:40	Min	49.693	1:00:00

